

# College Achieve Charter School

700 Grand Ave.  
Asbury Park, NJ 07712

## Analytical Results for Lead

JR Henderson Labs, Inc.  
123 Seaman Ave.  
Beachwood, NJ 08722  
732-341-1211  
Lab #15083

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	24-7362.11	JRH Labs	1	11/20/2024	07:40	200.9	11/22/2024	10:18	<2.00	2.00	1	N	
Cafeteria-Fountain	N	24-7362.12	JRH Labs	1	11/20/2024	07:40	200.9	11/22/2024	10:42	<2.00	2.00	1	N	
1st Floor-Flo Water	N	24-7362.13	JRH Labs	1	11/20/2024	07:40	200.9	11/22/2024	10:48	<2.00	2.00	1	N	
2nd Floor-Flo Water	N	24-7362.14	JRH Labs	1	11/20/2024	07:40	200.9	11/22/2024	10:54	<2.00	2.00	1	N	

# J.R. HENDERSON LABS, INC.

123 Seaman Ave.  
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis  
Atomic Absorption  
Gas Chromatography

(732) 341-1211  
FAX (732) 505-1658  
ID # 15083

State Certified  
Drinking Water Laboratory  
Consulting Service

College Achieve Charter School  
700 Grand Ave.  
Asbury Park, NJ 07712

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
24-7362.11	Field Blank	11-20-24	07:40	LEAD	200.9	<2.00	11-22-24	10:18	15
24-7362.12	Cafeteria-Fountain	11-20-24	07:40	LEAD	200.9	<2.00	11-22-24	10:42	15
24-7362.13	1st Floor-Flo Water	11-20-24	07:40	LEAD	200.9	<2.00	11-22-24	10:48	15
24-7362.14	2nd Floor-Flo Water	11-20-24	07:40	LEAD	200.9	<2.00	11-22-24	10:54	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.  
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).  
< = less than

Examined By: *Margaret Ellis*  
Lab Manager

Date: 12-3-24

# Chain of Custody

## POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

**CLIENT INFORMATION**

<b>Name:</b> College Achieve Charter School
<b>Address:</b> 700 Grand Ave, Asbury Park, NJ 07712
<b>Client Rep:</b> Michael Clark 732-774-0727

**LAB INFORMATION**

<b>Name:</b> JR Henderson Labs, Inc.
<b>Address:</b> 123 Seaman Ave., Beachwood, NJ 08722
<b>Lab Mgr.:</b> Trevor Ellis

**SCHOOL/PROJECT INFORMATION**

<b>Bldg :</b> College Achieve Charter School
<b>Bldg No:</b>
<b>Bldg Address:</b> 700 Grand Ave, Asbury Park, NJ 07712
<b>Contact Name &amp; Number:</b> Michael Clark 732-774-0727

**SAMPLE DATA – ID & Location must match container label**

LAB USE	Sample ID	Sampled Outlet Location	Date	Time (24hr)	First Draw	Flushed
	24-7362-11	Field Blank	11/20/2024	7:40	X	
	24-7362-12	CAFETERIA - FOUNTAIN	11/20/2024	7:40	X	
	24-7362-13	1ST FLOOR - FLOWATER	11/20/2024	7:40	X	
	24-7362-14	2ND FLOOR FLOWATER	11/20/2024	7:40	X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO<sub>3</sub> @ pH<2 to be preserved by lab

**CHAIN OF CUSTODY**

<b>Relinquished By:</b> <i>M. Clark</i>	<b>Date/Time:</b> 11/21/2024 9:12	<b>Received By:</b> <i>[Signature]</i>	<b>Date/Time:</b> 11/21/24 0912

**Method of shipment/delivery:**       Fed-Ex       Hand Delivery       Other: \_\_\_\_\_

**INSTRUCTIONS TO THE LABORATORY**

Analyze both initial and follow up samples <input type="checkbox"/> Other: <input checked="" type="checkbox"/> Follow QAPP instructions	<b>Lab:</b> JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722  <b>Contact:</b> Stacey Yuro syuro@henderson-labs.com	<b>Report Results to:</b> <input type="checkbox"/> Phone <input checked="" type="checkbox"/> Email: mclark@collegeachieve.org
---	--	--

**Comments:** Provide Laboratory Data Report (LDR) Package and Chain of Custody